

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150302-E226209  
**Report Reference** E226209-20150227  
**Issue Date** 2015-MARCH-02

**Issued to:** MIGATRON CORP  
935 DIECKMAN ST  
WOODSTOCK IL 60098

**This is to certify that  
representative samples of**

PROCESS CONTROL EQUIPMENT FOR USE IN  
HAZARDOUS LOCATIONS

Class I, Groups A, B, C and D, Class II, Groups E, F, and  
G, and Class III hazardous locations.

Model RPS-409A, followed by -1 through -999, followed by -  
IS3, may or may not be followed by -any alphanumeric  
characters; analog ultrasonic sensor is intrinsically safe  
when installed per Control Drawing No. 14122606.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**

Standard No. UL 913, Intrinsically Safe Apparatus and  
Associated Apparatus for Use in Class I, II, and III, Division  
1, Hazardous (Classified) Locations, Standard No.  
CAN/CSA C22.2 No. 157-92, Intrinsically Safe and Non-  
incendive Equipment for Use in Hazardous Locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at [www.ul.com/contactus](http://www.ul.com/contactus)

